

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI014566.01-R1
DATE: 12/05/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Polaris
CODE: 213-1
REVISION DATE: 11/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Polaris Technologies, Inc. 500 Victoria Road Austintown, OH 44515	Series "3030" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-2450mm(100") H-1524mm(60") Panel: W-1248mm(49.13") H-1422mm(56") DLO: W-1187mm(46.75") H-1359mm(53.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG20 2540 x 1524 (100 x 60)-HS Design Pressure: ±960 Pa (20 psf) Water Penetration Resistance Test Pressure: 360 Pa (5.43 psf)

Product Tested By: Molimo Architectural Product Testing
Report No: 2163.01-109-12
Expiration Date: November 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023