

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014588-R1
DATE: 12/18/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Beijing Mylch
CODE: 2350-1
REVISION DATE: 04/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Beijing Mylch Building Products Co., Ltd 1388 Lin Xian Road Jinshan District, Shanghai 201505	Series "SD118" Thermally-Broken Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1593mm(62.72") H-3120mm(122.83") DLO: W-1418mm(55.83") H-2942mm(115.83")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class AW-PG80 1593 x 3121 (63 x 123)-FW Design Pressure: ±3840 Pa (80 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek Testing Service Shenzhen Ltd.
Report No: 191104001SHF-001
Expiration Date: November 30, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023