

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014604-R1  
DATE: 12/26/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: Prime Window  
CODE: 2288-1  
REVISION DATE: 05/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>3400 Tacoma Street</b> <b>Union Gap, WA 98903</b>	<b>Series "720"</b> <b>Composite Casement/Fixed/Casement</b> <b>Over Triple Awnings, Wide T Bar</b>  Configuration: XOX/XXX Glazing: Insulating Glass (Annealed)  Frame: W-2426mm(95.5") H-2197mm(86.5") Vent: W-854mm(33.63") H-1770mm(69.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG35 2426 x 2197 (96 x 87)C/FW/AP</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Intertek (WA)  
Report No: J8273.01-901-44/F8005.02-901-44/E1438.02-801-47/E1449.02-801-47  
Expiration Date: **June 30, 2027**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)