

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014609-R2
DATE: 12/26/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2288-1
REVISION DATE: 05/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems 3400 Tacoma Street Union Gap, WA 98903	Series "720" Composite Twin Casement Over Twin Fixed, Narrow T-Bar Configuration: XX/OO Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-2426mm(95.5") Vent: W-876mm(34.5") H-1788mm(70.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG30 1816 x 2426 (72 x 96)-C-FW Design Pressure: ±1440 Pa (±30 psf) Canadian Air Infiltration/Exfiltration Level: A3 Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Intertek (WA)
Report No: J8275.01-901-44/E1438.02-801-47/E1449.02-801-47/W-2058
Expiration Date: June 30, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. M.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com