

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014619-R1
DATE: 01/07/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2288-1
REVISION DATE: 12/18/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems 3400 Tacoma Street Union Gap, WA 98903	Series "7000" Vinyl Casement Configuration: X Glazing: Exterior-Insulating Glass (Annealed) Interior-Monolithic (Annealed) Frame: W-914mm(36") H-2007mm(79") Vent: W-826mm(32.5") H-1930mm(76")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 914 x 2007 (36 x 79)-C Design Pressure: ±2400 Pa (±50 psf) Canadian Air Infiltration/Exfiltration Level: A3 Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: Intertek (WA)
Report No: K1966.001-901-44 R1
Expiration Date: September 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023