NOTICE OF	PRODUCT CERTIFIC	ATION
STATISTICS ACCREDITED AR CITOSS ACCREDITED AR ACCREDITED AR ACCREDITED AR ACCREDITED AR AR ACCREDITED AR AR ACCREDITED AR AR AR AR AR AR AR AR AR AR	CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:	<u>NI014639-R1</u> 01/27/2020 <u>Structural</u> Beijing Mylch 2350-1
	<b>REVISION DATE:</b>	04/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Beijing Mylch Building Products Co., Ltd		Series "S	D"
1388 Lin Xian Road	Thermally-Broken Aluminum		
Jinshan District, Shanghai 201505	Awning Window		
		Configuratio Glazing: Insulating Gla	
	Frame:	W-1597mm(62.87")	H-989mm(38.92")
	Vent:	W-1471mm(57.91")	H-861mm(33.9")
	DLO:	W-1360mm(53.54")	H-750mm(29.53")

SPECIFICATION		PRODUCT RATING	
AAMA/WDMA/CSA 101/I.S.2/A440-17		Class CW-PG50 1597 x 989 (63 x 39)-AP Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)	
Product Tested By:	Intertek Testing Service Shenzhen Ltd.		
Report No:	200109003SHF-001		

Report No: Expiration Date: 200109003SHF-001 January 31, 2027

She

Administrator's Signature:

## NATIONAL ACCREDITATION AND **MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023