

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014653-R1  
DATE: 01/28/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Beijing Mylch  
CODE: 2350-1  
REVISION DATE: 04/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Beijing Mylch Building Products Co., Ltd</b> <b>1388 Lin Xian Road</b> <b>Jinshan District, Shanghai 201505</b>	<b>Series "SD"</b> <b>Thermally-Broken Aluminum</b> <b>Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame: W-1597mm(62.87") H-3122mm(122.91") DLO: W-1418mm(55.83") H-2940mm(115.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG80 1597 x 3122 (63 x 123)-FW</b> <b>Design Pressure: ±3840 Pa (80 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b>

Product Tested By: Intertek Testing Service Shenzhen Ltd.  
Report No: 200115013SHF-001  
Expiration Date: January 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)