

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014688.01-R1
DATE: 02/13/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Solar Innovations
CODE: 872-1
REVISION DATE: 09/08/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	Series "SI5200 LeanTo G2 RV" Straight Eave Lean-to Sunroom w/(2) Gable Ends Configuration: Top - 0000/0000/0000 L Side - 000/000/000 R Side - 000/000/000 Front - 00 Glazing: Vertical IG 3/16" Tempered Glass/1/8" Heat Strengthened Glass/0.090 SentryGlas Plus Interlayer/ 1/8" Heat Strengthened Glass & Roof IG 3/16" Tempered Glass/1/8" Annealed Glass/0.090 SentryGlas Plus Interlayer/ 1/8" Annealed Glass Frame: D-2743mm(108") W-3708mm(146") D-2743mm(108") H-2743mm(108") DLO: W-803mm(31.63") H-1864mm(73.38")

SPECIFICATION	PRODUCT RATING
ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a	Design Pressure: 3830 Pa (80 psf) Wind Zone 4 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 110-20222-2
Expiration Date: April 30, 2026

A handwritten signature in black ink, appearing to be 'Shi' or similar.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122