

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014746.09-R2
DATE: 03/09/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Pella
CODE: 1735-1
REVISION DATE: 11/10/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Pella Corporation 102 Main Street Pella, IA 50219 | Glazed Inswing Fiberglass Side-Hinged Double Door Assembly w/Glazed Sidelites Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-2667mm(105") H- 2480mm(97.63") Panel: W-908mm(35.75") H-2413mm(95") DLO: W-533mm(21") H-2007mm(79") |

| SPECIFICATION | PRODUCT RATING |
|---------------------|---|
| ASTM E330-14 | Design Pressure: ±1680 Pa (35 psf) Qualifying Configurations: O/X/OX/XO/OXO/XX/OXX/XXO/OXXO |

Product Tested By: American Test Lab, Inc. (NC)
Report No: ATLNC 1219.01-19P
Expiration Date: **January 31, 2034**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023