

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014763-R1  
DATE: 03/23/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Acadia  
CODE: 317-1  
REVISION DATE: 04/04/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Acadia Windows &amp; Doors</b> <b>930 Todds Lane</b> <b>Rosedale, MD 21237</b>	<b>Series "4100"</b> <b>Vinyl Sliding Glass Door</b>  (w/Standard Sill)  Configuration: XO Glazing: Insulating Glass (Tempered)  Frame: W-2362mm(93") H-2311mm (91") Panel: W-1194mm(47") H-2235mm (88") DLO: W-991mm(36") H-2032mm(80")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class CW-PG50 2362 x 2311* (93 x 91*)-SD</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2640 Pa (55 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19399-4/NCTL-110-19399-2  
Expiration Date: March 31, 2032

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)