

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014776-R3
DATE: 04/07/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 11/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851 | Series "1000/1359" Vinyl Outswing Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-864mm(34") H-1905mm(75") Vent: W-819mm(32.25") H-1861mm(73.25") DLO: W-691mm(27.19") H-1732mm(68.19") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class LC-PG50 864 x 1905 (34 x 75)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23217-1/W-1979
Expiration Date: **March 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@naminc.com

NOPC-03/30/2023