

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014777-R2
DATE: 04/07/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 11/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "1000/1322" Vinyl Project-Out-Bottom Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-914mm(36") Vent: W-1172mm(46.13") H-867mm(34.13") DLO: W-1048mm(41.25") H-743mm(29.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG40 1219 x 914 (48 x 36)-AP Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23215-1/W-1979
Expiration Date: **March 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023