

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014819  
DATE: 04/10/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Moss  
CODE: 206-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Moss Supply Company</b> <b>5001 North Graham Street</b> <b>Charlotte, NC 28269</b>	<b>Series "7300"</b> <b>Vinyl Sliding Glass Door</b> <b>(New Construction)</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-2692mm(106") H-2019mm(79.5") Panel: W-899mm(35.38") H-1943mm(76.5") DLO: W-702mm(27.63") H-1746mm(68.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG40 2692 x 2019 (106 x 80)-SD</b> <b>Design Pressure: ±1915 Pa (40 psf)</b> <b>Positive Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC  
Report No: C8717.04-501-44  
Expiration Date: April 30, 2024

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122