

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI014869.01-R1</u>
DATE:	<u>05/12/2020</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>Sky-Frame</u>
CODE:	<u>2114-1</u>
REVISION DATE:	<u>01/11/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Sky-Frame, Inc. Langfeldstrasse 111 Frauenfeld, Switzerland CH-8500</p>	<p style="text-align: center;">Series "Sky-Frame 3" Thermally-Broken Aluminum Sliding Glass Door (3-Track w/Pocket)</p> <p style="text-align: center;">Configuration: XXOXXXP Glazing: IG- 1/4" Heat Strengthened Glass/0.090" Sentryglass Interlayer/1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.090" Sentryglass Interlayer/1/4" Heat Strengthened Glass</p> <p>Frame: W-16422mm(646.5") H-3887mm(153") Panel: W-2320mm(91.31") H-3510mm(138.19") DLO: W-2271mm(89.62") H-3474mm(136.75")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/WDMA/CSA 101/I.S.2/A440-17 TAS-201/202/203-94</p>	<p>Class CW-PG65 16422 x 3887 (647 x 153)-SD Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 1200 Pa (25.06 psf) Large Missile Impact Rated</p>

Product Tested By: Intertek, PLC
 Report No: I1185.01-301-44/I1187.02-301-44
 Expiration Date: **December 31, 2032**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/ Email: nami@namiinc.com