

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014869.02-R1
DATE: 05/12/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Sky-Frame
CODE: 2114-1
REVISION DATE: 01/11/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sky-Frame, Inc. Langfeldstrasse 111 Frauenfeld, Switzerland CH-8500	Series "Sky-Frame 3" Thermally-Broken Aluminum Sliding Glass Door (4-Track w/Pocket) Configuration: OOXXXXP Glazing: IG- 1/4" Heat Strengthened Glass/0.090" Sentryglass Interlayer/1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.090" Sentryglass Interlayer/1/4" Heat Strengthened Glass Frame: W-16417mm(646.34") H-3887mm(153") Panel: W-2320mm(91.31") H-3510mm(138.19") DLO: W-2271mm(89.62") H-3474mm(136.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 TAS-201/202/203-94	Class CW-PG65 16417 x 3887 (646 x 153)-SD Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 1200 Pa (25.06 psf) Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: I1185.01-301-44/I1187.02-301-44
Expiration Date: **December 31, 2032**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Email: nami@namiinc.com