

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014908.11-R1
DATE: 09/14/2020
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1
REVISION DATE: 01/09/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| ViWinTech Windows & Doors 2400 Irvin Cobb Drive Paducah, KY 42003 | Series "Grand Vista Sliding Door" Vinyl Multi-Slide/Pocket Sliding Door Impact Rated Configuration: OXXO Glazing: IG-Exterior 3/16" Tempered Glass/ Laminate-3/16" Annealed Glass/0.090" Trosifol PVB by Kuraray/3/16" Annealed Glass Frame: W-5023mm(197.75") H-2438mm(96") Panel: W-1276mm(50.25") H-2357mm(92.81") DLO: W-1098mm(43.25") H-2180mm(85.81") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05/09 | Class CW-PG45 5023 x 2438 (198 x 96)-SD Design Pressure: ± 2160 Pa (± 45 psf) Wind Zone 3-Missile Level D Water Penetration Resistance Test Pressure: 324 Pa (6.75 psf) No Sill Riser Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf) w/0.522" Sill Riser Water Penetration Resistance Test Pressure: 576 Pa (12.0 psf) w/1.440" Sill Riser Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf) w/1.940" Sill Riser |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4143-03A-VWT
Expiration Date: April 30, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Email: nami@namiinc.com