

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014909.01-R3
DATE: 07/20/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "1630H" Thermally-Broken Aluminum Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-2311mm(91") Sash: W-1346mm(53") H-1143mm(45") Panel: W-1273mm(50.13") H-1060mm(41.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	H-C50 1422 x 2311 (56 x 91) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D7205.02-501-44
Expiration Date: **July 31, 2026**

A handwritten signature in black ink, appearing to be "S.H.D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023