

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014910.01-R3
DATE: 07/20/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "4500 Hopper" Thermally-Broken Aluminum Hopper Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-914mm(36") Vent: W-1470mm(57.88") H-860mm(33.88") DLO: W-1346mm(53") H-737mm(29")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class AW-PG90 1524 x 914 (60 x 36)-AP Design Pressure: ±4320 Pa (90 psf) Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B9310.01-602-44
Expiration Date: **July 31, 2026**

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023