NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014913-R3**
DATE:	**07/20/2020**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Wojan**
CODE:	**2087-1**
REVISION DATE:	**03/03/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation **217 Stover Road** **Charlevoix, MI 49720**	**Series "5500/5540"** **Thermally-Broken Aluminum** **Out-Swing Terrace Door** Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2438mm(96") Panel: W-1113mm(43.81") H-2375mm(93.5") DLO: W-892mm(35.13") H-2156mm(84.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class AW-PG40 1219 x 2438 (48 x 96)-ATD** **Design Pressure: ±1920 Pa (40 psf)** **Water Penetration Resistance Test Pressure: 390 Pa(8.15 psf)**

Product Tested By: Molimo, LLC
Report No: 1717.01-106-11
Expiration Date: **July 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com