

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014920-R1
DATE: 07/29/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2287-1
REVISION DATE: 03/14/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems 12775 East 38th Avenue Denver, CO 80239	Series "4500" Vinyl Muller Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-2438mm(96") H-2489mm(98") DLO: W-1073mm(42.25") H-2353mm(92.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 2438 x 2489 (96 x 98)-FW Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C9360.05-109-47
Expiration Date: **June 30,2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023