

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014922-R1  
DATE: 07/29/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Prime Window  
CODE: 2287-1  
REVISION DATE: 03/14/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>12775 East 38<sup>th</sup> Avenue</b> <b>Denver, CO 80239</b>	<b>Series "4500" Glazed</b> <b>Vinyl Out-Swing Side-Hinged Door</b>  Configuration: XX Glazing: Insulating Glass (Tempered)  Frame: W-2032mm(80") H-2489mm(98") Panel: W-959mm(37.75") H-2407mm(94.75") DLO: W-727mm(28.63") H-2178mm(85.75")

8

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG30 2032 x 2489 (80 x 98)-SHD</b> <b>Design Pressure: ±1440 Pa (±30 psf)</b> Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: D1376.07-109-47  
Expiration Date: **June 30,2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023