

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI014939-R1
DATE: 08/24/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Pacific Crest
CODE: 2516-1
REVISION DATE: 08/28/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pacific Crest Building Products 4227 South Meridian, C-114 Puyallup, WA 98373	Series "W28" Glazed Wood Inswing Side-Hinged Door w/Sidelites (Continuous Head and Sill) Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1753mm(69") H-2070mm(81.5") Panel: W-1067mm(42") H-2006mm(79") DLO: W-137mm(5.38") H-1629mm(64.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 1753 x 2070 (69 x 82)-LWSHDX Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: K4307.01-901-44/I9563.01-301-44/W-1952
Expiration Date: August 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com