

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014941-R1
DATE: 08/24/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Pacific Crest
CODE: 2516-1
REVISION DATE: 08/28/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Pacific Crest Building Products 4227 South Meridian, C-114 Puyallup, WA 98373 | Series "M23C" Glazed Wood Inswing Side-Hinged Door w/Sidelites (Continuous Head and Sill) Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1638mm(64.5") H-2070mm(81.5") Panel: W-914mm(36") H-2007mm(79") DLO: W-137mm(5.38") H-1629mm(64.13") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class R-PG45 1638 x 2070 (65 x 82)-LWSHDX Design Pressure: ±2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) |

Product Tested By: Intertek, PLC
Report No: I9562.01-301-44/K4309.01-901-44/W-1952
Expiration Date: August 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com