

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014951.01-R1
DATE: 09/02/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Asselin
CODE: 417-1
REVISION DATE: 07/29/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Asselin, Inc. 2870 Peachtree Road Northwest, #714 Atlanta, GA 30305	Series "Inswing Double Casement Type E" Wood Inswing Casement Window Configuration: XX Glazing: IG- (Laminated Annealed/Tempered) Frame: W-1649mm(64.94") H-2249mm(88.56") Vent: W-749mm(29.5) H-2159mm(85") DLO: W-635mm(25") H-2000mm(78.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 1651 x 2261 (65 x 89)-C Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 252 Pa (5.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4186-2
Expiration Date: August 31, 2029

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com