

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014952-R1
DATE: 09/02/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Asselin
CODE: 417-1
REVISION DATE: 07/29/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Asselin, Inc. 2870 Peachtree Road Northwest, #714 Atlanta, GA 30305	Series "Inswing French Door" Inswing Wood Side-Hinged Door Configuration: X Glazing: IG- (Laminated Annealed/Tempered) Frame: W-2200mm(86.63") H-3048mm(120") Panel: W-1048mm(41.25") H-2997mm(118") DLO: W-918mm(36.13") H-2746mm(108.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 2210 x 3048 (87 x 120)-SHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 252 Pa (5.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4186-5
Expiration Date: August 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com