

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015020  
DATE: 10/21/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "P1570/P157NAW3V"</b> <b>Vinyl Triple Awning Vertical Window</b>  Configuration: X/X/X Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-2743mm(108") Sash: W-1170mm(46.06") H-875mm(34.44") DLO: W-1045mm(41.13") H-752mm(29.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG50 1219 x 2743* (48 x 108*)-AP</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL 110-23555-1/ATI D9203.01-109-47  
Expiration Date: June 30, 2024

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122