

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015103-R1  
DATE: 12/01/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Pacific Crest  
CODE: 2516-1  
REVISION DATE: 08/28/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Pacific Crest Building Products</b> <b>4227 South Meridian, C-114</b> <b>Puyallup, WA 98373</b>	<b>Series "M55"</b> <b>Glazed Wood Inswing Side-Hinged Door</b> <b>w/Sidelites</b>  (Continuous Head and Sill)  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1638mm(64.5") H-2070mm(81.5") Panel: W-914mm(36") H-2007mm(79") DLO: W-660mm(26") H-221mm(8.7")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG50 1638 x 2070 (65 x 82)-LWSHDX</b> <b>Design Pressure: <math>\pm 2400</math> Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek, PLC  
Report No: K4309.01-901-44/I9563.01-301-44/K4307.01-901-44/  
I9562.01-301-44/W-1952  
Expiration Date: **August 31, 2027**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)