

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015108
DATE: 12/03/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Domadeco
CODE: 2704-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Domadeco, Inc. 7455 Arroyo Crossing, Suite 220 Las Vegas, NV 89113	Series "Inswing Entrance Door" Steel Opaque Single Inswing Side Hinged Door Configuration: X Frame: W-1003mm(39.50") H-2089mm(82.25") Panel: W-949mm(37.38") H-2048mm(80.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a/E1996-14a TAS 202-94 (Structural Only) TAS 201-94/TAS 203-94	Class R-PG50 1003 x 2089 (39 x 82)-SHD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: L1613.01-201-18/L1613.02-201-18/L1613.03-201-18
Expiration Date: **July 31, 2024**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122