

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015120  
**DATE:** 12/09/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Intus  
**CODE:** 1817-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Intus Windows, LLC</b> <b>2720 Prosperity Avenue, 400-1</b> <b>Fairfax, VA 22031</b>	<b>Series "L18"</b> <b>Polymer Dual Action Window</b>  Configuration: X  Glazing: Insulating Glass (Tempered)  Frame: W-1200mm(47.25") H-2000mm(78.75") Vent: W-1124mm(44.25") H-1924mm(75.75") DLO: W-968mm(38.13") H-1772mm(69.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG70 1200 x 2000 (47 x 79)-DAW</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC  
Report No: L2020.01-109-44  
Expiration Date: **July 31, 2024**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122