

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015123.01-R1
DATE: 12/10/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Plastpro
CODE: 1108-1
REVISION DATE: 03/14/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Plastpro, Inc. 4747 Kister Court Ashtabula, OH 44004	Series "Plastpro Insert Glazing Series" Fiberglass 6/8 Inswing Door w/PVC Edge, Insert Glazing, Glazed Sidelites, and Adjustable Cap Configuration: OXO Glazing: Insulated Glass (Tempered) Frame: W-2850mm(112.19") H-2081mm(81.94") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class R-PG40 2850 x 2081 (112 x 82)-SHD Design Pressure: 1920 Pa (40 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16786-5
Expiration Date: December 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023