

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015123.02-R1  
**DATE:** 12/10/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Plastpro  
**CODE:** 1108-1  
**REVISION DATE:** 03/14/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Plastpro, Inc.</b> <b>4747 Kister Court</b> <b>Ashtabula, OH 44004</b>	<b>Series "Plastpro Insert Glazing Series"</b> <b>Fiberglass 6/8 Outswing Door w/PVC Edge,</b> <b>Insert Glazing, and Glazed Sidelites</b>  Configuration: OXO Glazing: Insulated Glass (Tempered) Frame: W-2850mm(112.19") H-2061mm(81.13") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>A440S1-09</b>	<b>Class R-PG40 2850 x 2061 (112 x 81)-SHD</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Positive Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-16786-6  
Expiration Date: **December 31, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023