<b>NOTICE OF PROD</b>	<b>DUCT CERTIFICA</b>	ΓΙΟΝ
TOSS ACCREDITED AS		
W JOND PAR OC	<b>CERTIFICATION NO:</b>	NI015124.01-R1
OSI CONTRACTOR	DATE:	12/10/2020
(* CER	<b>TIFICATION PROGRAM:</b>	Structural
That a ship	COMPANY:	Plastpro
CERTIFICS DRODUC	CODE:	<u>1108-1</u>
TED PRO	<b>REVISION DATE:</b>	03/14/2024
v w		

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com.</u> NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Plastpro, Inc.	Series "Plastpro Insert Glazing Series"	
4747 Kister Court	Fiberglass 8/0 Inswing Door w/PVC Edge,	
Ashtabula, OH 44004	Insert Glazing, and Adjustable Cap	
	Configuration: XX Glazing: Insulated Glass (Tempered)	
	Frame: W-1878mm(73.94") H-2488mm(97.94")	
	Panel: W-908mm(35.75") H-2419mm(95.25")	
	DLO: W-533mm(21") H-2007mm(79")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class R-PG20 1878 x 2488 (74 x 98)-SHD Design Pressure: 960 Pa (20 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.00 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Report No: Expiration Date:

National Certified Testing Laboratories NCTL-110-16786-2 December 31, 2028

Sh

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023