

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015124
DATE: 07/01/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Steves and Sons Corporation 201 Humble Avenue San Antonio, TX 78225	Series "Legacy 4140 Smooth" In-Swing Glazed Full-Lite Fiberglass Side-Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.5") H-2064mm(81.25") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-245mm(9.63") H-381mm(15")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG60 953 x 2070 (37.5 x 81.5) LW-SHDX Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.0 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23629-1
Expiration Date: **March 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122