

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015239  
DATE: 04/28/2021  
CERTIFICATION PROGRAM: Fire  
COMPANY: JELD-WEN  
CODE: 1822-1  
EXPIRATION DATE: 04/30/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>"ABS 20-Minute"</b> <b>Routed Particleboard Fire Door</b> Manufacturer Specific Fire Doors for Single Swing Installation in 20-Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>20-Minute Single Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10C (2009)</b>	<b>20 Minute-Positive Pressure</b> <b>Without Hose Stream</b> <b>Category B - Additional Edge-Sealing</b> <b>System Required</b>

TEST REPORT
<b>Intertek Test Report No: 3107376COQ-004, 3169105, 3043898, 102245905, 104375792</b>

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122