

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015333-R1
DATE: 07/19/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Solar
CODE: 872-1
REVISION DATE: 04/10/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	Series "SI 5008 2x4" Aluminum Curtain Wall Configuration: OO/O Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090" Sentry Glas Plus Interlayer/3/16" Annealed Glass Frame: W-3100mm(122") H-2286mm(90") DLO: W-1473mm(58") H-2184mm(86")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a	Class CW-PG65 3100 x 2286 (122 x 90)-FW Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf) Canadian Air Infiltration/Exfiltration Level: Fixed Wind Zone 4 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23309-1/NCTL-110-23309-2
Expiration Date: April 30, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023