

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015336.01
DATE: 07/25/2021
CERTIFICATION PROGRAM: Structural
COMPANY: CGI Impact
CODE: 2750-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
CGI Impact Resistant Windows & Doors 3780 West 104th Street Hialeah, FL 33018	Series "PW3120V" Impact Rated Vinyl Fixed Window Configuration: O Glazing: IG-Exterior-1/8" Annealed Glass or 1/8" Tempered Glass/Interior-Laminate-1/8" Annealed Glass/0.045" Trosifol PVB by Kuraray/ 1/8" Annealed Glass Frame: W-832mm(32.75") H-1822mm(71.75") DLO: W-753mm(29.63") H-1743mm(68.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a/19/E1996-17/20	Class CW-PG50 832 x 1822 (33 x 72)-FW Design Pressure: ±2394 Pa (±50 psf) Wind Zone 2-Missile Level C Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)

Product Tested By: FTL-FL
Report No: FTL 21-2042
Expiration Date: March 31, 2025

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122