

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015343.01
DATE: 07/27/2021
CERTIFICATION PROGRAM: Structural
COMPANY: CGI Impact
CODE: 2750-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
CGI Impact Resistant Windows & Doors 3780 West 104th Street Hialeah, FL 33018	Series "HR3110V" Impact Rated Vinyl Horizontal Slider Configuration OX Glazing: IG-Exterior-1/8" Annealed or 1/8" Tempered Glass/Interior-Laminate-1/8" Annealed Glass/0.045" Trosifol PVB by Kuraray/1/8" Annealed Glass Frame: W-1873mm(73.75") H-1372mm(54") Panel: W-910mm(35.81") H-1310mm(51.56") DLO: W-865mm(34.06") H-1292mm(50.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a/19/E1996-17/20	Class LC-PG50 1873 x 1372 (74 x 54)-HS Design Pressure: ±2394 Pa (±50 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf) Wind Zone 2-Missile Level C

Product Tested By: FTL-FL
Report No: FTL 21-1046/21-1045
Expiration Date: May 31, 2025

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122