

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012672.03-R1
DATE: 05/24/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 10/03/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation U.S.A. 8989 North Loop East Houston, TX 77029	Series "XX Gliding Patio Door" Fiberglass Sliding Glass Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1810mm(71.25") H-2019mm(79.5") Panel: W-908mm(35.75") H-1945mm(76.59") DLO: W-667mm(26.25") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-17	Class R-PG35 1810 x 2019 (71 x 80)-SD Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 252 Pa(5.25 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4200-1
Expiration Date: March 31, 2035

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023