

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013462-R1  
DATE: 01/03/2017  
CERTIFICATION PROGRAM: Fire  
COMPANY: Straight Line  
CODE: 1898-1  
REVISION DATE: 04/05/2021  
EXPIRATION DATE: 01/31/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Straight Line Millwork &amp; Supply, Inc.</b> <b>1315 North Jog Road, Suite 101</b> <b>West Palm Beach, FL 33413</b>	<b>20 Minute Positive Pressure</b> <b>Flush or Molded Interior Side-Hinged</b> <b>Door w/Wheatboard Core</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1999)</b> <b>UL 10(b) (1997/2009)</b> <b>CAN4-S104 (1985)</b> <b>UBC Standard 7-2 (1994/1997)</b> <b>UL 10(c) (2009)</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B Door-Additional Edge Seal</b> <b>Required</b> <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: 3137714COQ-008</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122