

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013766.05-R2
DATE: 06/28/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Soft-Lite
CODE: 2336-1
REVISION DATE: 06/03/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Soft-Lite Windows 10250 Phillip Parkway Streetsboro, OH 44241	Series "Barcelona" Vinyl Horizontal Sliding Window (TSL 30I) Configuration: XOX Glazing: IG-1/8" Annealed Glass/Laminate-0.106" Annealed Glass/0.090" Saflex PVB Interlayer/0.106" Annealed Glass or 1/8" Tempered Glass/Laminate-0.106" Annealed Glass/0.090" Saflex PVB Interlayer/0.106" Annealed Glass Frame: W-2819mm(111") H-1600mm(63") Sash: W-933mm(36.75") H-1480mm(58.25") DLO: W-832mm(32.75") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2394 Pa (50 psf) Positive Design Pressure: 2394 Pa (50 psf) Negative Design Pressure: 2633 Pa (55 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 03001870
Expiration Date: June 30, 2027

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Email: nami@namiinc.com

NOPC-03/30/2023