

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013788.01-R2
DATE: 07/19/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Soft-Lite
CODE: 2336-1
REVISION DATE: 06/03/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Soft-Lite Windows 10250 Phillip Parkway Streetsboro, OH 44241	Series "PW30" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1930mm(76") DLO: W-1054mm(41.5") H-1765mm(69.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1219 x 1930 (48 x 76)-FW Design Pressure: ±2400 Pa (50 psf) Water Penetration resistance Test Pressure: 470 Pa (9.82 psf)

Product Tested By: Farabaugh Engineering and Testing, Inc.
Report No: T203-17
Expiration Date: June 30, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com