

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013806-R1
DATE: 08/08/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Solar
CODE: 872-1
REVISION DATE: 04/09/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Solar Innovations, Inc. 31 Roberts Road Pine Grove, PA 17963	Series "SI7000" Thermally-Broken Aluminum Mulled Fixed Window Configuration: O Glazing: IG-3/16" Tempered Glass/1/8" Tempered Glass/0.090" PVB Interlayer/1/8" Tempered Glass Frame: W-1524mm(60") H-1524mm(60") DLO: W-1391mm(54.75") H-1391mm(54.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a	Class CW-PG80 1524 x 1524 (60 x 60)-FW Design Pressure: ±3968 Pa (80 psf) Water Penetration Resistance Test Pressure: 718 Pa (15.0 psf) Wind Zone 4 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-19999-1/NCTL-110-19999-2
Expiration Date: March 31, 2025

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122