

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014160.04-R1
DATE: 08/31/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Survivalite
CODE: 1872-1
REVISION DATE: 07/26/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Survivalite Impact Window Systems, LLC 1385 Morningside Drive Mount Dora, FL 32757	Series "Survivalite Fixed" Aluminum Fixed Window Configuration: O Glazing: IG-1/4" Annealed Glass/1/4" Polycarbonate/ 0.025" Clear Film Interlayer/1/4" Polycarbonate/0.025" Clear Film Interlayer/1/8" Polycarbonate/0.025" Clear Film Interlayer/1/8" Polycarbonate Frame: W-597mm(23.5") H-597mm(23.5") DLO: W-432mm(17") H-432mm(17")

SPECIFICATION	PRODUCT RATING
ICC 500-14 ASTM E330-14	Passed Design Pressure: +110/-130 psf

Product Tested By: Blackwater Testing, Inc.
Report No: BT-SIS-20-002
Expiration Date: December 31, 2025

Administrator's Signature: _____


**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com