

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014208-R2  
DATE: 09/17/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Glass Craft  
CODE: 1157-1  
REVISION DATE: 0719/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Glass Craft Door Corporation</b> <b>2002 Brittmoore</b> <b>Houston, TX 77043-2209</b>	<b>Series "Hardwood Glazed Double TDL Doors"</b> <b>Glazed Wood In-Swing &amp; Out-Swing Side-Hinged Door Assembly</b>  w/True Divided Lites  Configuration: XXX Glazing: Insulating Glass (Tempered)  Frame: W-2883mm (113.5") H-2502mm(98.75") Panel: W-914mm (36") H-2438mm(96") DLO: W-273mm (11") H-778mm(30.63")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b>	<b>Design Pressure: ±2880 Pa (±60 psf)</b>

Product Tested By: Intertek, PLC  
Report No: H4307.01-801-44  
Expiration Date: **September 30, 2025**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122