

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014420-R5  
**DATE:** 05/23/2019  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** Builders First  
**CODE:** 2479-1  
**REVISION DATE:** 09/07/2023  
**EXPIRATION DATE:** 05/31/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Builders First Source</b> <b>8809 Paul Starr Road</b> <b>Pensacola, FL 32514</b>	<b>20 Minute Fiberglass Reinforced Faced</b> <b>Door w/Proprietary Core</b> <b>(Simulated Panel Type or Flush)</b> Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations <b>Single Door Maximum Size: 3'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UL 10C (2009)</b> <b>NFPA 252 (2008)</b> <b>CAN4 S104 (1985)</b>	<b>20 Minute-with Hose Stream</b> <b>Positive Pressure</b> <b>Category A- No Additional Edge Sealing</b> <b>Required</b>

## TEST REPORT

**Intertek Test Report No: J20051379-231, 3084465, 317611MID-002,  
3187023MID-002, & 10035435MID-001**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)