

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014421-R5
DATE: 05/23/2019
CERTIFICATION PROGRAM: Fire
COMPANY: Builders First
CODE: 2479-1
REVISION DATE: 09/07/2023
EXPIRATION DATE: 05/31/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Builders First Source 8809 Paul Starr Road Pensacola, FL 32514	20 Minute SmoothStar Fiberglass Door w/Proprietary Core (Simulated Panel Type or Flush) Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2009)(R2015) NFPA 252 (2012)	20 Minute-without Hose Stream Positive Pressure Category B- Additional Edge Sealing Required

TEST REPORT

**Intertek Test Report No: 3033943, 3084465, 3176111MID-002,
3187023MID-002, 100354358MID-001, 100537989MID-001 & 102613119MID-004**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com