NOTICE OF PRODUCT CERTIFICATION |



CERTIFICATION NO: NI014656-R5

DATE: 01/30/2020

CERTIFICATION PROGRAM: <u>Fire</u>

COMPANY: Builders First

CODE: 2479-1

REVISION DATE: <u>09/07/2023</u> **EXPIRATION DATE:** <u>02/28/2026</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Builders First Source Corporation | Endura 20 Minute Category C |
| 8809 Paul Starr Road | Proprietary Wood Door Frames |
| Pensacola, FL 32514 | |
| | Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations |
| | Single Door Maximum Size: 3'0" x 8'0" |
| | Minimum Thickness: 4-9/16" |

| SPECIFICATION | PRODUCT RATING | |
|--|---|--|
| NFPA 252 (1995) UL 10b (1997)(2009) CAN/ULC S104 (1980)(2010) UBC Standard 7-2 (1994) | 20 Minute-With Hose Stream Neutral Pressure Category C- Proprietary Frame | |
| TEST REPORT | | |
| Intertek Test Report No(s): J98027188-231 | | |

Shi

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com