

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014656-R6
DATE: 01/30/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Builders First
CODE: 2479-1
REVISION DATE: 02/25/2026
EXPIRATION DATE: 02/28/2029

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Builders First Source Corporation 8809 Paul Starr Road Pensacola, FL 32514	Endura 20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Thickness: 4-9/16"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1995) UL 10b (1997)(2009) CAN/ULC S104 (1980)(2010) UBC Standard 7-2 (1994)	20 Minute-With Hose Stream Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): J98027188-231

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com