

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014662.03-R2  
**DATE:** 05/03/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/15/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "4701"</b> <b>Aluminum Fixed Window</b>  Configuration: O Glazing: Monolithic-3/16" Annealed Glass/0.105" Eastman PVB Interlayer/3/16" Annealed Glass  Frame: W-1324mm (52.13") H-1803mm (71") DLO: W-1229mm (48.38") H-1708mm (67.25")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +80/-80 psf</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Molimo  
Report No: 2264.01-106-11-R2  
Expiration Date: **December 31, 2024**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)