

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014662.04-R1
DATE: 05/03/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 10/26/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4701" Aluminum Fixed Window Configuration: O Glazing: Monolithic-3/16" Heat Strengthened Glass/0.105" Eastman PVB Interlayer/3/16" Heat Strengthened Glass Frame: W-2699mm (106.25") H-1349mm (53.13") DLO: W-2623mm (103.25") H-1270mm (50")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +80/-80 psf Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) Large Missile Impact Rated

Product Tested By: Molimo
Report No: 2264.02-106-11/2128.01-106-11
Expiration Date: **December 31, 2024**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com